

Responses to EPA Questions Regarding the Steam Electric Questionnaire

14. In Part F Section 5, you should have included a section for SPD-4, SPD-6, and SPD-7 as well. If you did not include these because you do not perform groundwater monitoring on these pond/impoundments, just state this. However, if you do perform groundwater monitoring on these ponds please complete all questions in Part F Section 5 for these ponds.

There are monitoring wells on the north and south sides of SPD-4, specifically, MP-12P, MP-13P, MP-14P, and MP-15P. Locations of these monitoring wells are indicated on the map included with the original submittal. Answers for Part F, Section 5 have also already been submitted for these monitoring wells as they were included as part of the well monitoring system for SPD-1.

SPD-6 and SPD-7 are both stormwater ponds at the ash landfill-2. There are monitoring wells surrounding the landfill, but not for the specific purpose of monitoring the stormwater pond. Information regarding the monitoring wells surrounding the landfill-2 has already been submitted for your review.

15. In question F5-3 for landfill-1, landfill-2, and SPD-1, you put SD4 as one of the pollutants. Please clarify what you mean by this.

SD4 is a typo, it should have been SO₄.